



No. 22- Afarand St.-Sattar khan St.-
Tehran-I.R. Iran, Postal Code: 1441653161
Tel. & Fax: +98 21 66925763-66946386
Email: info@irrup.com
Website: www.irrup.com

APZ-SHARIF INC.



Safety; Your Desire, Our Solution

CERTIFICATE OF CONFORMANCE SAFETY VALVES

CUSTOMER INFORMATION

Customer: Sirjan Iranian Steel Co.
Customer I.D:

Serial No.: 10608194
Tag No.: 53022

PRODUCT SPECIFICATIONS

Nominal Size:	4×6 Inch	Flow Area:	2855.8 mm ²
Medium:	Gas	Body Material:	1.7357 WC6
Marked Set Pressures:	48.26 barg	CDTP:	48.26 barg
Pressure Rating:	inlet: 600 lbs A	Outlet:	150 lbs A

TESTING/MARKING INFORMATION

Set Pressure Test: (Test procedure standard: ISO 4126-1)

Set Pressure (barg)	Test Medium	Date	Valve Function
48	Nitrogen	1/1/2022	Accept

Leakage Test: (Test procedure standard: API 527)

Test Pressure (barg)	Test Medium	Max. Allowable Leak Rate (Bubbles/min)	Leak Rate (Bubbles/min)	Result
43.4	Nitrogen	20	0	Pass

Notes:

FINAL APPROVAL

S. Azimi
Quality Control Manager

Sign: _____

Date: 2 January, 2022

M. Khajepour
Department Manager

Sign: _____

Date: 2 January, 2022



IRRUP SAFETY SYSTEMS